ROGERS FIRE PROTECTION CO.

Central Ohio · Licensed & Insured · Serving Ohio since 1979

FREE SELF-CHECK CHECKLIST

Backflow Assembly Self-Check

A basic visual check between your required annual test. Testing the assembly itself requires a certified tester and gauge -- this is only a look-and-listen check.

Recommended frequency: Quarterly

- [ ] Assembly is accessible and not blocked by storage or landscaping
- [ ] No visible leaks at the assembly or surrounding piping
- [ ] Shutoff valves appear undisturbed and in the correct position
- [ ] No unusual discharge from the relief valve
- [ ] Current test tag/certification is present and legible

Anything that didn't look right, or any area you couldn't access this time:

See something that doesn't look right?

Call (614) 526-4995 · michael@rogersfp.com · www.rogersfp.com