



Exit & Emergency Lighting Monthly Self-Check

NFPA 101 calls for a monthly functional check of every exit sign and emergency light -- most units have a push-to-test button that makes this quick.

Recommended frequency: Monthly

- ☐ Exit sign is illuminated and clearly legible
- ☐ Pressing the test button causes emergency lights to activate
- ☐ Light heads actually illuminate the egress path, not just each other
- ☐ Egress path below each unit is unobstructed
- ☐ Housing and lenses are undamaged, with no cracks or missing covers

Note the location of any unit that didn't activate or looked damaged:

See something that doesn't look right?

Call (614) 526-4995 · info@rogersfp.com · www.rogersfp.com