



# Fire Alarm Monthly Self-Check

A basic visual and status check you can do without any special training. Anything electrical or functional beyond this list needs a licensed technician -- that's what your scheduled NFPA 72 testing covers.

## Recommended frequency: Monthly

- ☐ Control panel shows a normal status with no active trouble or supervisory lights
- ☐ Pull stations are visible, unobstructed, and undamaged
- ☐ Smoke and heat detectors are unobstructed (nothing hung or stacked near them)
- ☐ Notification devices (horns/strobes) are unobstructed and undamaged
- ☐ No unexplained beeping or trouble signal from the panel
- ☐ Panel documentation/inspection tag is present and reasonably current

**Anything that didn't look right, or any area you couldn't access this time:**

---

---

---

---

---

---

---

**See something that doesn't look right?**

Call (614) 526-4995 · [michael@rogersfp.com](mailto:michael@rogersfp.com) · [www.rogersfp.com](http://www.rogersfp.com)