



Fire Extinguisher Monthly Self-Check

The exact items NFPA 10 expects a facility to check monthly, on top of your annual professional service. Takes under a minute per extinguisher.

Recommended frequency: Monthly

- ☐ Extinguisher is in its designated location, unobstructed and visible
- ☐ Pressure gauge (or indicator) reads in the operable range
- ☐ Pull pin and tamper seal are intact
- ☐ Nozzle and hose are unobstructed and free of damage
- ☐ Shell shows no corrosion, dents, or visible damage
- ☐ Inspection tag is present and up to date
- ☐ Mounting bracket is secure and at the correct height

Note the location/ID of any extinguisher that failed a check above:

See something that doesn't look right?

Call (614) 526-4995 · info@rogersfp.com · www.rogersfp.com