



Private Fire Hydrant Self-Check

A basic visual check between your annual professional flow test -- especially worth doing after landscaping changes or snow season.

Recommended frequency: Quarterly

- ☐ Hydrant is visible and unobstructed by parking, storage, landscaping, or snow
- ☐ No visible leaks at the hydrant body or base
- ☐ Outlet caps are present and appear operable
- ☐ Hydrant is painted/visible for identification at night
- ☐ Ground around the hydrant is stable, with no settling or damage

Anything that didn't look right, or any area you couldn't access this time:

See something that doesn't look right?

Call (614) 526-4995 · michael@rogersfp.com · www.rogersfp.com