



Fire Pump Weekly Self-Check

NFPA 25 calls for a weekly visual check of the pump room and controller, on top of your professional annual flow test.

Recommended frequency: Weekly

- ☐ Pump room is accessible, heated, and free of standing water
- ☐ Controller shows no active alarm or trouble lights
- ☐ Pilot/power indicator lights show normal status
- ☐ No visible leaks around the pump or piping
- ☐ Fuel and oil levels look adequate (diesel-driven pumps only)

Anything that didn't look right, or any area you couldn't access this time:

See something that doesn't look right?

Call (614) 526-4995 · michael@rogersfp.com · www.rogersfp.com