ROGERS FIRE PROTECTION CO.
Central Ohio · Licensed & Insured · Serving Ohio since 1979

FREE SELF-CHECK CHECKLIST

# Fire Sprinkler Monthly Self-Check

A quick visual walk-through between your professional inspections. This isn't a substitute for licensed testing -- it's a way to catch an obvious problem (like a closed valve) months before your next scheduled visit.

**Recommended frequency: Monthly**

- ☐ All control valves are open and free of obvious damage
- ☐ Valve seals, locks, or supervisory devices look undisturbed
- ☐ Pressure gauges are reading in the normal range (not zero, not pegged high)
- ☐ No visible leaks, corrosion, or damage on exposed piping
- ☐ Nothing is stored within 18 inches of sprinkler heads or deflectors
- ☐ Sprinkler heads are unobstructed, undamaged, and free of paint or coatings
- ☐ Fire department connection (FDC) caps are in place and the connection is accessible
- ☐ Spare sprinkler cabinet and wrench are present and stocked

**Anything that didn't look right, or any area you couldn't access this time:**

## See something that doesn't look right?

Call (614) 526-4995 · michael@rogersfp.com · www.rogersfp.com